

TEL (020) 8937 5190
EMAIL jill.nesbit@brent.gov.uk
WEB <http://www.brent.gov.uk>

OUR REF: Aachi Chettinad

DATE: 25th February 2014

Vijay Alagesan
Aachi Chettinad
213 Central Apartments
455 High Road
Wembley
Middlesex
HA9 7AF

Licensing Act 2003
Application for a Premises Licence
Aachi Chettinad, 545 High Road, Wembley, Middlesex, HA0 2DJ

Dear Sirs

I refer to your application on for a Premises Licence for the above named premises and my subsequent visit to the premises, and my discussions with the Manager the following works are in the process of being carried out. Please can you advise when these works have been completed. They include: -

1. Replacement of the rear push bar fire door with the correct push bar to open sign on it in the lower ground floor to ensure there are no locks or latches on it to prevent adequate access if necessary. (I was advised this was on order)
2. Highlighting tape should be applied to the small step on the door to the emergency exit so that people are aware there is a small step and a mind the step sign would be useful.
3. The rear alleyway next to the emergency exit door shall be kept free from objects to prevent emergency access.

Once these works have been carried out and in accordance to the drawings submitted to us related to the Application, the Public Safety Team make a Representation to the Licensing Authority on the grounds of Public Safety.

Providing you are willing accept the proposed licence conditions the Public Safety Team would withdraw the Representation:-

Licence Conditions

- The maximum number of persons permitted within the ground floor of the premises shall not exceed **35** including staff.

- The maximum number of persons within the lower ground floor of the premises shall not exceed **40** including staff.
- Any locks or flush latches on exit doors shall be unlocked and kept free from fastenings other than push bars whilst the public are on the premises.
- Any socket outlets (or other power supplies used for DJ equipment, band equipment and other portable equipment) that are accessible to performers, staff or the public shall be suitably protected by a residual current device (RCD having a rated residual operating current not exceeding 30 milliamps).

In order for the Public Safety Team to withdraw this representation, it will be necessary for you or your client to **confirm in writing** that the above works have been rectified and that you accept the above licence conditions.

We will require these conditions to appear on the licence schedule should the licence be granted.

If you or your client requires further clarification please do not hesitate to contact me.

Yours faithfully

Jill Nesbit
Public Safety Officer
Consumer & Business Protection