



REGENERATION AND GROWTH

Regulatory Services
Brent Civic Centre, Engineers Way,
Wembley, Middlesex. HA9 0FJ

Tel: (020) 8937 5252
Direct Line 020-8937 5190
Fax: (020) 8937 5150
Email: environmentandprotection@brent.gov.uk
Web: www.brent.gov.uk
Date: 26/05/2015

Mr Williams
The Centre @ NW10
71-73 High Street
Harlesden
London
NW10 4NS

Your Ref:
Our Ref: PS/08148/15
Contact: Jill Nesbit

Dear Mr Williams,

Licensing Act 2003
Application for a Premises Licence
First and Second Floors, 71-73 High Street, London, NW10 4NS

I refer to your application on for a Premises Licence for the above named premises. In accordance to the drawings submitted to us on 28/04/2015 related to the Application and my subsequent visit, the Public Safety Team makes a Representation to the Licensing Authority on the grounds of Public Safety.

Providing you are willing accept the proposed licence conditions the Public Safety Team would withdraw the Representation:-

Licence Conditions

- The maximum number of persons within the premises shall not exceed 200 including staff & performers.
- Any locks or flush latches on exit doors shall be unlocked and kept free from fastenings other than push bars whilst the public are on the premises.
- Any socket outlets (or other power supplies used for DJ equipment, band equipment and other portable equipment) that are accessible to performers, staff or the public shall be suitably protected by a residual current device (RCD having a rated residual operating current not exceeding 30 milliamps).
- Directional emergency exit signage shall be placed throughout the premises showing the nearest available exit.

- All emergency exit routes shall remain clear and unblocked whilst public are on the premises
- The final exit gate at the bottom of the external stairs shall be free from fastenings other than push bars.
- PUSH BAR TO OPEN signage shall be placed on the relevant doors.

In order for the Public Safety Team to withdraw this representation, it will be necessary for you or your client to **confirm in writing** that the above works have been rectified and that you accept the above licence conditions.

We will require these conditions to appear on the licence schedule should the licence be granted.

If you or your client requires further clarification please do not hesitate to contact me.

Yours sincerely,

Jill Nesbit
Environmental Protection Officer
Regeneration and Growth