

**Public Safety Team Objection to Premises review application  
Greenes, 362-364 Neasden Lane North, NW10**

The public safety team wishes to put in a representation for this review following my visit to the premises and propose the following conditions to be considered for inclusion on the licence at committee stage.

- 1) The maximum number of persons permitted on the premises shall not exceed 60 not including staff.
- 2) The inward opening front entrance/exit door to the bar area shall be fixed back in the open position when the public are on the premises
- 2) Any locks or latches on exit doors, shutter or gates shall be unlocked and kept free from fastenings other than push bars or pads whilst the public are on the premises.
- 3) Appropriate emergency exit signage shall be installed within both bar and pool room areas and on exit doors to ensure any person on the premises is aware of emergency exit routes.
- 4) The exit door from the pool room area shall only be used as a fire/emergency exit if an appropriate push bar door is installed or the door is locked in the open position at all times whilst public are on the premises
- 5) Any socket outlets (or other power supplies used for DJ equipment, band equipment and other portable equipment) that are accessible to performers or staff shall be suitably protected by a residual current device (RCD having a rated residual operating current not exceeding 30 milliamps).

Jill Nesbit  
Public Safety Officer  
Regulatory Services  
Brent Civic Centre

Tel. 020 8937 5190  
Email: [jill.nesbit@brent.gov.uk](mailto:jill.nesbit@brent.gov.uk)