



REGENERATION AND GROWTH

Regulatory Services
Brent Civic Centre, Engineers Way,
Wembley, Middlesex. HA9 0FJ

Tel: (020) 8937 5252
Direct Line 020-8937 5190
Fax: (020) 8937 5150
Email: environmentandprotection@brent.gov.uk

Web: www.brent.gov.uk

Date: 06/08/2015

Craig Baylis
BERWIN LEIGHTON PAISNER
ADELAIDE HOUSE
LONDON BRIDGE
LONDON
EC4R 9HA

Your Ref:
Our Ref: SR/14766/15
Contact: Jill Nesbit

Dear Mr Baylis,

Licensing Act 2003

**Application for a Premises Licence -
271-273 Kilburn High Road, London, NW6 7JR**

I refer to your application on for a Premises Licence for the above named premises. In accordance to the scaled drawings submitted to us in related to the Application, the Public Safety Team make a Representation to the Licensing Authority on the grounds of Public Safety.

Providing you are willing accept the proposed licence conditions the Public Safety Team would withdraw the Representation:-

Licence Conditions

- The maximum number of persons within the premises shall not exceed **60** including staff.
- Any locks or flush latches on exit doors shall be unlocked and kept free from fastenings other than push bars whilst the public are on the premises.
- The front door and 2 internal conservatory doors into the main restaurant shall remain fixed in the open position whilst the public are on the premises so as to ensure an unobstructed means of escape. Alternatively the doors can be changed to open in the direction of escape
- The furthest points in the rear garden are over the maximum travel distance of 18m to a storey exit therefore use of the garden is not permitted.
- Suitable emergency exit signage and emergency lighting shall be provided throughout the main premises and conservatory areas.

- Any socket outlets (or other power supplies used for DJ equipment, band equipment and other portable equipment) that are accessible to performers, staff or the public shall be suitably protected by a residual current device (RCD having a rated residual operating current not exceeding 30 milliamps).

In order for the Public Safety Team to withdraw this representation, it will be necessary for you or your client to **confirm in writing** that the above works have been rectified and that you accept the above licence conditions.

We will require these conditions to appear on the licence schedule should the licence be granted.

If you or your client requires further clarification please do not hesitate to contact me.

Yours sincerely,

Jill Nesbit
Public Safety Officer
Regeneration and Growth