



Public Safety Team
Regeneration and Growth
Brent Civic Centre
Engineers Way
Wembley
HA9 0FJ

TEL (020) 8937 5364
EMAIL colin.wickes@brent.gov.uk
WEB <http://www.brent.gov.uk>
OUR REF: 223438138
YOUR REF:

DATE: 4th November 2015

Mr Kuppasamy Kirupagaran
Crystal Club
1 Popin Business Centre
Southway
Wembley
HA9 0HB

Licensing Act 2003
Application for a Premises Licence
2 Popin Business Centre South Way Wembley HA9 0HF

Dear Mr Kirupagaran

I refer to your application for Premises Licence for the above named premises. In accordance to the drawing submitted to us in relation to the application, the Public Safety Team make a revised Representation to the Licensing Authority on the grounds of Public Safety.

Providing you are willing to accept the following proposed licence conditions the Public Safety Team would withdraw the Representation:-

Licence Conditions

- The maximum number of persons permitted in the Ground Floor Bar area shall not exceed **60** including staff.
- Any locks or flush latches on exit doors shall be unlocked and kept free from fastenings other than push bars whilst the public are on the premises.
- Any socket outlets (or other power supplies used for DJ equipment, band equipment and other portable equipment) that are accessible to performers or staff shall be suitably protected by a residual current device (RCD having a rated residual operating current not exceeding 30 milliamps).

In order for the Public Safety Team to withdraw this representation, it will be necessary for you to **confirm in writing or via Email** that you accept the above licence conditions.

We will require these conditions to appear on the licence schedule should the licence be granted.

Please Note: The capacity of this premises has been estimated in accordance with The Building Regulations, Technical Regulations for Places of Public Entertainment and on the basis that there is only one outward opening exit door leading into the final exit/entrance 2 and the scanned scaled drawing does appear to be accurate.

If you require further clarification please do not hesitate to contact me.

Yours faithfully

Colin Wickes
Principal Public Safety Officer
Regulatory Services
Regeneration and Growth
Brent Council