



REGENERATION AND GROWTH

Regulatory Services
Brent Civic Centre, Engineers Way,
Wembley, Middlesex. HA9 0FJ

Tel: (020) 8937 5252
Direct Line 020 8937 5364
Fax: (020) 8937 5150
Email: environmentandprotection@brent.gov.uk
Web: www.brent.gov.uk
Date: 29/10/2015

Mr Kapoor
Personal Licence Courses Ltd
Studio 8
Hayes Business Studio, Hayes Campus
College Way Hayes UB3 3BB

Your Ref:
Our Ref: SR/18796/15
Contact: Colin Wickes

Dear Mr Kapoor,

Licensing Act 2003
Application for a Premises Licence
13 Wembley Hill Road, Wembley, HA9 8AF

I refer to your application on behalf of your client for a Premises Licence for the above named premises. In accordance to the drawings submitted to us on 23/10/2015 related to the Application, the Public Safety Team make a Representation to the Licensing Authority on the grounds of Public Safety.

Providing you are willing accept the proposed licence conditions the Public Safety Team would withdraw the Representation:-

Licence Conditions

- The maximum number of persons within the premises shall not exceed 35 not including staff.
- Any locks or flush latches on exit doors shall be unlocked and kept free from fastenings other than push bars whilst the public are on the premises.

In order for the Public Safety Team to withdraw this representation, it will be necessary for you or your client to **confirm in writing** or Email that you accept the above licence conditions.

We will require these conditions to appear on the licence schedule should the licence be granted.

If you or your client requires further clarification please do not hesitate to contact me.

Yours sincerely,

Colin Wickes

Principal Public Safety Officer
Regeneration and Growth