



Regulatory Services
Regeneration and Environmental
Services
Brent Civic Centre
Engineers Way
Wembley
HA9 OFJ

TEL (020) 8937 5364
EMAIL colin.wickes@brent.gov.uk
WEB <http://www.brent.gov.uk>
OUR REF: 223518464
YOUR REF: AC/GRO.13.1

DATE: 11TH January 2016

Thomas and Thomas
Partners LLP
38A Monmouth Street
London
WC2H 9EP

Licensing Act 2003
Application for a Premises Licence
Burger Fi Unit 17 Building 1 Wembley Central Shopping Centre HA9 7AJ

Dear Sir/Madam

I refer to your application on behalf of your client for a Premises Licence for the above named premises. In accordance to the drawing (number BUR-WEM-201) submitted to us in relation to the application, the Public Safety Team make a Representation to the Licensing Authority on the grounds of Public Safety.

Providing you and your client are willing to accept the following proposed licence conditions the Public Safety Team would withdraw the Representation:-

Licence Conditions

- The maximum number of persons permitted in the Ground Floor Restaurant shall not exceed **100**, not including staff.
- The maximum number of persons in the External seated area at the front entrance to the Restaurant shall not exceed **14**, not including staff.
- Any locks or flush latches on exit doors shall be unlocked and kept free from fastenings other than push bars whilst the public are on the premises.

In order for the Public Safety Team to withdraw this representation, it will be necessary for you or your client to **confirm in writing or via Email** that you accept the above licence conditions.

We will require these conditions to appear on the licence schedule should the licence be granted.

If you require further clarification please do not hesitate to contact me.

Yours faithfully

Colin Wickes
Principal Public Safety Officer
Regulatory Services
Regeneration and Environmental Services
Brent Council