



SYMBOL	FIRE (GRAY) ARCHITECTURAL ITEMS
⊙	FIRE DOOR KEEP LOCKED SHUT.
⊙	FIRE DOOR KEEP SHUT.
⊙	AUTOMATIC FIRE DOOR KEEP CLEAR.
⊙	FIRE EXIT KEEP CLEAR.
⊙	FIRE SHUTTER KEEP CLEAR.
⊙	SYNCHRO OVERFLOW SIGN.
⊙	GREASE TRAP SIGN.
⊙	RUNNING MAN SYMBOL, FIRE EXIT WARDING & ARROW TO DIRECTION OF NEAREST FIRE EXIT DOOR.
⊙	RUNNING MAN SYMBOL, FIRE EXIT WARDING & ARROW TO DIRECTION OF NEAREST FIRE EXIT DOOR.
⊙	RUNNING MAN SYMBOL, FIRE EXIT WARDING & ARROW TO DIRECTION OF NEAREST FIRE EXIT DOOR.
⊙	RUNNING MAN SYMBOL, FIRE EXIT WARDING & ARROW TO DIRECTION OF NEAREST FIRE EXIT DOOR.
⊙	RUNNING MAN SYMBOL, FIRE EXIT WARDING & ARROW TO DIRECTION OF NEAREST FIRE EXIT DOOR.
⊙	RUNNING MAN SYMBOL, FIRE EXIT WARDING & ARROW TO DIRECTION OF NEAREST FIRE EXIT DOOR.
⊙	DOOR DELAY SIGN.
⊙	NO ACCESS! AUTHORISED PERSONNEL ONLY.
⊙	PERMIT TO WORK.
⊙	NO ACCESS NO STORAGE.
⊙	FIRE ALARM PANEL, BREAK GLASS UNIT FOR OPERATION KEY ALSO TO BE SUPPLIED & INSTALLED.
⊙	ACCESS ONLY NO STORAGE.
⊙	FIRE ALARM CONTROL PANEL, BREAK GLASS UNIT FOR OPERATION KEY ALSO TO BE SUPPLIED & INSTALLED.
⊙	SMOKE VENT PANEL, BREAK GLASS UNIT FOR OPERATION KEY ALSO TO BE SUPPLIED & INSTALLED.
⊙	FIRE RAY COMPRESSOR.
⊙	CHURCH WHEEL LOCKS ARE IN PLACE UNDER H.V. REAR WHEELS.
⊙	PUSH BAR TO OPEN.
⊙	FIRE ACTION SIGN.
⊙	DOOR LOCKED, PLEASE PUSH BELL FOR ASSISTANCE. WAIT FOR BUZZER TO SOUND BEFORE OPENING DOOR.
⊙	ROOF SAFETY SIGN.
⊙	DANGER OF DEATH.
⊙	ROOF SAFETY SIGN.
⊙	DO NOT ENTER YELLOW SECTION OF ROOF UNLESS WEARING SECURED SAFETY HARNESS. REFER TO DRAWING FOR DETAILED LOCATION.
⊙	D.C.T.V. IN OPERATION.

CONTRIBUTORS ARE NOT TO SCALE DIMENSIONS FROM THIS DRAWING

SAFETY HEALTH & ENVIRONMENT INFORMATION
 Based on the use of experienced and competent contractors working to an approved method statement unusual residual hazards/risks are listed below or the statement 'No Unusual Risks'

CONSTRUCTION:
 C1. No Unusual Risk

OPERATIONS:
 O1. No Unusual Risk

MAINTENANCE:
 M1. No Unusual Risk

(FUTURE) DEMANTLING/DEMOLITION:
 D1. No Unusual Risk

NOTES:
 1. THIS DRAWING IS TO BE USED FOR INFORMATION ON FIRE PRECAUTIONS ONLY.
 FOR CONSTRUCTION & DIMENSIONED LAYOUT REFER TO DWG. H03/01/15

2. FIRE DOORS
 ALL OPENINGS FOR CABLES PASSING THROUGH COMPARTMENT WALLS & FLOORS & ALL OPENINGS FOR SERVICE PIPEWORK & DUCTS PASSING THROUGH COMPARTMENT WALLS & FLOORS TO BE PROTECTED WITH FIBREGLASS FIRE BATT & PENETRATION COATINGS TO ACCORDANCE WITH MANUFACTURERS RECOMMENDATION FOR BATT & PEN. FOR LOCATION OF WALL PENETRATION REFER TO MECHANICAL & ELECTRICAL ENGINEERS DRAWINGS.

3. FIRE RESISTANCE
 FOR DETAILS OF FIRE REPORT, PLEASE REFER TO FIRE ENGINEERING REPORT. DOCUMENT REFERENCE TX 8697, SER. ONE, DATED 06/10/15. PRODUCED BY 'TRENTHAM FIRE LTD'.

4. EXTERNAL FIRE EXIT DOORS TO SALES FLOOR AREA
 ALL EXTERNAL FIRE EXIT DOORS TO THE SALES FLOOR AREA TO HAVE A MINIMUM PERIOD OF FIRE RESISTANCE OF ONE HOUR.

SYMBOL	MECHANICAL & ELECTRICAL ITEMS
⊙	AREA COVERED BY HEAT DETECTORS. (NOT INDICATED REFER TO M&E & ELEC. DWGS.)
⊙	AREA COVERED BY SMOKE DETECTORS. (NOT INDICATED REFER TO M&E & ELEC. DWGS.)
⊙	FIRE ALARM REPEATER PANEL. (INDICATED FOR INFORMATION ONLY)
⊙	FIRE EXIT (UNLIMITED) SIZE 300 x 150mm. (INDICATED FOR INFORMATION ONLY)
⊙	FIRE ALARM PANEL. (INDICATED FOR INFORMATION ONLY)
⊙	SPRINKLER PANEL. (INDICATED FOR INFORMATION ONLY)
⊙	INDEPENDENT EMERGENCY LIGHTING POINT. (INDICATED FOR INFORMATION ONLY)
⊙	2KG CARBON DIOXIDE 1/2 EXTINGUISHER. (SUPPLIED & INSTALLED BY COSTCO)
⊙	ULTRA-ASTE FOAM SPRAY/ULTRA-TEMPERATURE EXTINGUISHER. (SUPPLIED & INSTALLED BY COSTCO)
⊙	1900 2/300 FIRE BLANKET. (SUPPLIED & INSTALLED BY COSTCO)
⊙	FIRE ALARM CALL POINT.

SYMBOL	ARCHITECTURAL ITEMS
⊙	DOORS WITH PANIC FASTENERS.
⊙	DOORS WITH VISION PANELS.
⊙	15 MIN FIRE RESISTING DOOR.
⊙	1 HOUR FIRE RESISTING DOOR.
⊙	2 HOUR FIRE RESISTING DOOR.
⊙	1 HOUR FIRE RESISTING / SMOKE RESISTING WALL (REFER TO NOTES).
⊙	1 HOUR FIRE RESISTING / SMOKE RESISTING FLOOR EDGE TREATMENT.
⊙	MAGNETIC DOOR HOLDER.
⊙	STEEL COLLARS & INTERMEDIATE BEAMS TO BE FIRE PROTECTED TO 1 HOUR FIRE RESISTANCE WITH WHITE INTUMESCENT PAINT TO SUIT SIZE OF STEELWORK.
⊙	DOOR TO HAVE 15 MIN FIRE RESISTANCE AS SHOWN MANUFACTURER DELAYED EGRESS.
⊙	ALL JUMP PENETRATIONS (THRU) TO HAVE 1 HOUR FIRE RESISTING COLLARS.

⊙	ZONE OUTSIDE 4m TRAVEL DISTANCE.
⊙	FOOD & HANDWARE TO BE STORED IN MAXIMUM STORAGE HEIGHT + 1m.
⊙	CENTRE & MACHINES MAXIMUM STORAGE HEIGHT.

Revision Table:

Rev	Description	By	Date
C	Updated to latest floor plan drawing no (03)01 Rev C	GB	23.09.15
B	Updated to latest floor plan & boundary condition revised to gridline A	GB	26.08.15
A	Construction Issue	GB	10.07.15

BroadwayMalyan^{RM}
 Architectural Urbanism Design

Rev Room: 10 High Street
 Trade: Reading
 Building: R07 SAN

T: +44 (0)118 932 3466
 F: +44 (0)118 932 3461
 C: Roy@broadwaymalyan.com
 www.broadwaymalyan.com

Client:
 Costco Wholesale UK Ltd.
 Project:
 Wembley

Description:
 Proposed Fire Precautions Plan
 (with Fit Out Works Overlay)

Scale:
 Construction
 1:200@A0

Date:
 GB
 July 2015

Job Number:
 28115

Drawing Number:
 (03)03

Sheet:
 C

Original size 150mm @ A0. Copyright Broadway Malyan Limited