



Public Safety Team  
Community Protection  
Brent Civic Centre  
Engineers Way  
Wembley  
HA9 0FJ

TEL (020) 8937 5190  
EMAIL [jill.nesbit@brent.gov.uk](mailto:jill.nesbit@brent.gov.uk)  
WEB <http://www.brent.gov.uk>

OUR REF: 223595441

DATE: 23<sup>rd</sup> May 2016

Mr Rocha  
Unit 35  
Battersea Business Centre  
99-101 Lavender Hill  
London  
SW11 5QL

**Licensing Act 2003**  
**Application for a Premises Licence**  
**O Castelo, 988-992 Harrow Road, London, NW10 5NT**

Dear Mr Rocha,

I refer to your application for a Premises Licence for the above named premises. In accordance to the drawings submitted to us related to the Application, the Public Safety Team make a Representation to the Licensing Authority on the grounds of Public Safety.

Providing you are willing accept the proposed licence conditions the Public Safety Team would withdraw the Representation:-

**Licence Conditions**

- The maximum number of persons permitted within the premises shall not exceed **80** not including staff.
- Any locks or flush latches on exit doors shall be unlocked and kept free from fastenings other than push bars whilst the public are on the premises.
- Any socket outlets (or other power supplies used for DJ equipment, band equipment and other portable equipment) that are accessible to performers, staff or the public shall be suitably protected by a residual current device (RCD having a rated residual operating current not exceeding 30 milliamps).

In order for the Public Safety Team to withdraw this representation, it will be necessary for you or your client to **confirm in writing** that the above works have been rectified and that you accept the above licence conditions.

We will require these conditions to appear on the licence schedule should the licence be granted.

If you or your client requires further clarification please do not hesitate to contact me.

Yours faithfully

Jill Nesbit  
Public Safety Officer  
Consumer & Business Protection