



Public Safety Team  
Community Protection  
Regeneration & Environmental  
Services  
Brent Civic Centre  
Engineers Way  
Wembley  
HA9 0FJ

TEL (020) 8937 5267  
FAX  
EMAIL [Pollen.exeter@brent.gov.uk](mailto:Pollen.exeter@brent.gov.uk)  
WEB <http://www.brent.gov.uk>  
OUR REF: 223664793

Ms Nakera Buchanan

[REDACTED]  
[REDACTED]  
[REDACTED]

DATE: 18 October 2016

E-mail: [REDACTED]

Dear Ms Buchanan

**Licensing Act 2003  
Application for a New Premises Licence  
Coco BS, 110 High Road, Willesden NW10 2PN**

I refer to your application for a premises licence for the above premises. The Public Safety Team is making a Representation to the Licensing Authority on the grounds of public safety.

Providing you are willing to accept the following proposed licence condition the Representation will be withdrawn.

**Licence Condition**

1. The socket outlets or other power supplies used for DJ equipment, band equipment and other portable equipment that are accessible to performers, staff or the public shall be suitably protected by a residual current device (RCD) having a rated residual operating current not exceeding 30 milliamps.

In order for the Public Safety Team to withdraw this representation, it will be necessary for you to **confirm in writing or via Email** that you accept the above licence condition.

We will require this condition to appear on the licence schedule should the licence be granted.

Please let me know if I can assist you further.

Yours sincerely

A handwritten signature in black ink, appearing to read "Pol Exeter".

Pol Exeter  
Public Safety Manager