



Public Safety Team
Community Protection
Regeneration & Environmental
Services
Brent Civic Centre
Engineers Way
Wembley
HA9 0FJ

TEL (020) 8937 5267
EMAIL Pollen.exeter@brent.gov.uk
WEB <http://www.brent.gov.uk>

Dear Mr Michael Stuart

OUR REF: 223684384

[REDACTED]
[REDACTED]
[REDACTED]

DATE: 6 December 2016

Email: [REDACTED]

Dear Mr Stuart

Licensing Act 2003
Application for a New Premises Licence
The Corrib Rest, 76-78 Salusbury Road, London NW6 6PA

I refer to your application for a premises licence for the above premises. The Public Safety Team is making a Representation to the Licensing Authority on the grounds of public safety.

Providing you are willing to accept the following proposed licence condition the Representation will be withdrawn.

Licence Conditions

1. Any locks or flush latches on exit doors and gates shall be unlocked and kept free from fastenings whilst the public are on the premises.
2. Any socket outlets (or other power supplies used for DJ equipment, band equipment and other portable equipment) that are accessible to performers or staff shall be suitably protected by a residual current device (RCD having a rated residual operating current not exceeding 30 milliamps).

In order for the Public Safety Team to withdraw this representation, it will be necessary for you to **confirm in writing or via Email** that you accept the above licence condition.

We will require this condition to appear on the licence schedule should the licence be granted.

Please note that the setting of the capacity for the premises and means of escape in case of fire is dealt with by the London Fire Brigade and you are advised to contact them regarding those matters.

Please let me know if I can assist you further.

Yours sincerely

Pol Exeter
Public Safety Manager