



Public Safety Team
Community Protection
Regeneration & Environmental
Services
Brent Civic Centre
Engineers Way
Wembley
HA9 0FJ

036 Limited
c/o Mr Abiodun Adeniyi
Kemp House
160 City Road
London
EC1V2NX

TEL (020) 8937 1031
EMAIL Chris.pearce@brent.gov.uk
WEB <http://www.brent.gov.uk>

OUR REF: **223708510**

DATE: 13th January 2016

Dear Mr Adeniyi

Licensing Act 2003
Application for a New Premises Licence
Premises address 036, 47 Cricklewood Broadway, London, NW2 3JX

I refer to your application for a premises licence for the above premises. The Public Safety Team is making a Representation to the Licensing Authority on the grounds of public safety.

Providing you are willing to accept the following proposed licence condition the Representation will be withdrawn.

Licence Condition

1. The socket outlets or other power supplies used for DJ equipment, band equipment and other portable equipment that are accessible to performers, staff or the public shall be suitably protected by a residual current device (RCD) having a rated residual operating current not exceeding 30 milliamps.
2. Remove the sudden and imperceptible change in the floor level between the restaurant and bar/restrooms/kitchen to prevent trips and falls to customers and staff. If this is not possible provide a ramp to minimise the sharpness of the change in level.

In order for the Public Safety Team to withdraw this representation, it will be necessary for you to **confirm in writing or via Email** that you accept the above licence condition.

We will require this condition to appear on the licence schedule should the licence be granted.

Please see a photo of the floor as discussed during my visit.



Please note that the setting of the capacity for the premises and means of escape in case of fire is dealt with by the London Fire Brigade and you are advised to contact them regarding those matters.

If you are in control of any part of a commercial premise, you are under a legal obligation to carry out a detailed fire risk assessment to identify risks and hazards in the premises. A fire risk assessment is essential in keeping your premises safe for everyone. You must keep a written record of your fire risk assessment if your business has five or more people.

More information can be found here: <http://www.london-fire.gov.uk/FireRiskAssessment.asp>

Please let me know if I can assist you further.

Yours sincerely

A handwritten signature in cursive script that reads "Chris Pearce".

Mr Chris Pearce
Public Safety Officer