

Dear Peter

Thank you for your correspondence dated the 14 February 2018, stating that you accept the conditions set out in our representation.

I confirm that the Public Safety Team now withdraw the current representation and do not make any further representations regarding the application.

Kind regards

Mr Chris Pearce  
Public Safety Officer  
Community Protection  
Regeneration & Environmental Services  
Brent Council  
020 8937 1031

[www.brent.gov.uk](http://www.brent.gov.uk)  
[@Brent\\_Council](#)

**From:** Peter Howson [<mailto:peter.howson@delipod.uk>]

**Sent:** 14 February 2018 13:18

**To:** Pearce, Chris <[Chris.Pearce@brent.gov.uk](mailto:Chris.Pearce@brent.gov.uk)>; Business Licence <[business.licence@brent.gov.uk](mailto:business.licence@brent.gov.uk)>; Legister, Linda <[Linda.Legister@brent.gov.uk](mailto:Linda.Legister@brent.gov.uk)>

**Subject:** New Premises - Delipod Hub (The Cafe Only), The Library at Willesden Green, 95 High Road, NW10 2SF - 10755

Dear Chris,

Thank you for taking the time to understand what we are trying to achieve and our premises.

I accept all of the conditions listed below.

Regards,  
Peter

**From:** Pearce, Chris [<mailto:Chris.Pearce@brent.gov.uk>]

**Sent:** 13 February, 2018 1:50 PM

**To:** 'Peter Howson' <[peter.howson@delipod.uk](mailto:peter.howson@delipod.uk)>; Business Licence <[business.licence@brent.gov.uk](mailto:business.licence@brent.gov.uk)>; Legister, Linda <[Linda.Legister@brent.gov.uk](mailto:Linda.Legister@brent.gov.uk)>

**Subject:** RE: New Premises - Delipod Hub (The Cafe Only), The Library at Willesden Green, 95 High Road, NW10 2SF - 10755

Dear Mr P Howson

**RE: Licensing Act 2003, Application for the Grant of a New Premises - Delipod Hub (The Cafe Only), The Library at Willesden Green, 95 High Road, NW10 2SF - 10755**

I refer to the application for a new licence for the above named premises. After assessing the reviewed information, the Public Safety Team will be making the following representations to the Licensing Authority on the grounds of Public Safety.

- Exits are not obstructed (including by curtains, hangings or temporary decorations), and accessible via non-slippery and even surfaces, free of trip hazards and clearly identified.
- The locks and flush latches on the exit doors and gates shall be unlocked and kept free from fastenings other than push bars or pads whilst the public are on the premises.
- The socket outlets (or other power supplies used for DJ equipment, band equipment and other portable equipment) that are accessible to performers, staff or the public shall be suitably protected by a residual current device (RCD having a rated residual operating current not exceeding 30 milliamps).
- Where chairs and tables are provided, internal gangways are kept unobstructed
- Temporary electrical wiring and distribution systems are not provided without notification to the licensing authority at least ten days before commencement of the work and/or prior inspection by a suitable qualified electrician.
- Subject to risk assessment, the maximum number of persons permitted on the Premises (not including staff) shall be: 60 persons when only Exit door one (1) is in use.
- Subject to risk assessment, the maximum number of persons permitted on the Premises (not including staff) shall be: 100 persons when only Exit door one (1) and two (2) are in use.
- Exit doors will be as defined in plan WGLC- Cafe License Plan-4 attached

In order for the Public Safety Team to withdraw this representation, it will be necessary for you or your client to confirm in writing or via Email that you accept the above licence conditions.

We will require these conditions to appear on the licence schedule should the licence be granted.

A fire risk assessment is essential in keeping your premises safe for everyone. You must keep a written record of your fire risk assessment if your business has five or more people. More information can be found here:

<http://www.london-fire.gov.uk/FireRiskAssessment.asp>

Kind regards

Mr Chris Pearce  
Public Safety Officer  
Community Protection  
Regeneration & Environmental Services  
Brent Council  
020 8937 1031