

From: ENS Public Safety
Sent: 12 November 2018 13:33
To: 'ARKA LICENSING' <contact@arkalicensing.co.uk>; ENS Public Safety <ens.publicsafety@brent.gov.uk>
Cc: Business Licence <business.licence@brent.gov.uk>; Legister, Linda <Linda.Legister@brent.gov.uk>
Subject: RE: CONSULT - Variation - 535 High Road, Wembley, HA0 2DJ - 13802

Dear Mr Suresh

Thank you for your correspondence dated 12th November, stating that you accept the conditions set out in our representation.

I confirm that the Public Safety Team now withdraw the current representation and do not make any further representations regarding the application.

We will require the agreed conditions to appear on the licence schedule

Please ensure a copy of the fire risk assessment is provided as soon as it is available.

Kind regards

Mr Chris Pearce
Public Safety Officer
Regeneration & Environmental Services
Brent Council

From: ARKA LICENSING
Sent: 12 November 2018 11:49
To: ENS Public Safety
Cc: Business Licence
Subject: Re: CONSULT - Variation - 535 High Road, Wembley, HA0 2DJ - 13802
Importance: High

Dear Chris,

Thank you for your email.

We hereby confirm that applicant has accepted all your conditions stated.

Applicant also has been carrying out fire risk assessment and report should be available soon.

Regards

Nira Suresh

Consultant
Arka Licensing

From: ENS Public Safety
Sent: 30 October 2018 16:04
To: 'ARKA LICENSING' ; ENS Public Safety
Subject: RE: CONSULT - Variation - 535 High Road, Wembley, HA0 2DJ - 13802

Dear Sirs

I refer to the application for a new licence for the above named premises. After assessing the application, the Public Safety Team will be making the following representations to the Licensing Authority on the grounds of Public Safety.

Please note that the setting of the capacity for the premises and means of escape in case of fire are dealt with by the London Fire Brigade and you are advised to contact them regarding those matters. Please forward a copy of your fire safety risk assessment to include your expected capacity including your exit capacity based on your fire escape width and calculations explaining how you reached that capacity.

Providing the licensee is willing to accept the following conditions Public Safety Team would withdraw the representation.

- The locks and flush latches on the exit doors and gates shall be unlocked and kept free from fastenings other than push bars or pads whilst the public are on the premises.
- The socket outlets (or other power supplies used for DJ equipment, band equipment and other portable equipment) that are accessible to performers, staff or the public shall be suitably protected by a residual current device (RCD having a rated residual operating current not exceeding 30 milliamps).
- Exits are not obstructed (including by curtains, hangings or temporary decorations), and accessible via non-slippery and even surfaces, free of trip hazards and clearly identified
- Where chairs and tables are provided, internal gangways are kept unobstructed

In order for the Public Safety Team to withdraw this representation, it will be necessary for you or your client to **confirm in writing or via Email** that you accept the above licence conditions.

We will require these conditions to appear on the licence schedule should the licence be granted.

If you are in control of any part of a commercial premise, you are under a legal obligation to carry out a detailed fire risk assessment to identify risks and hazards in the premises. A fire risk assessment is essential in keeping your premises safe for everyone. You must keep a written record of your fire risk assessment if your business has five or more people.

More information can be found here: <http://www.london-fire.gov.uk/FireRiskAssessment.asp>

Please let me know if I can assist you further.

Kind regards

Mr Chris Pearce
Public Safety Officer
Regeneration & Environmental Services
Brent Council