

### Appendix 3

<b>Lean Conservation Measures</b>	<b>Tudor Gardens</b>	<b>Short Break centre</b>	<b>Library at Willesden</b>	<b>John Billam Centre</b>	<b>Willow Childrens Centre</b>	<b>Northwich Park Sports Pavilion</b>	<b>Preston Park Sports Pavilion</b>	<b>Gordon Brown Centre</b>	<b>Ealing Road Library</b>	<b>Barham Park complex</b>
Draught proofing to windows and doors	x	x	x		x	x	x	x	x	x
Improved glazing						x	x	x	x	x
Floor insulation						x	x	x		
Wall insulation						x	x	x	x	
Roof Insulation						x	x	x	x	x

<b>Clean Conservation Measures</b>	<b>Tudor Gardens</b>	<b>Short Break centre</b>	<b>Library at Willesden</b>	<b>John Billam Centre</b>	<b>Willow Childrens Centre</b>	<b>Northwich Park Sports Pavilion</b>	<b>Preston Park Sports Pavilion</b>	<b>Gordon Brown Centre</b>	<b>Ealing Road Library</b>	<b>Barham Park complex</b>
LTHW pipework insulation	x	x	x	x	x	x			x	x
Replace toilet extract fans with MVHR	x	x			x	x	x	x	x	
Hot Water - point of use heaters			x	x	x		x			
Upgrade building controls to allow remote operation	x	x			x	x	x	x	x	x
Variable speed drives			x		x	x			x	
Heating - zone control valves										x
Heating - Electric Radiant Heating						x	x	x		
Ground Source Heat Pump						x				

Table 4: Example of measures for ten of the proposed buildings