



Public Safety Team
Environment and Protection
Brent Civic Centre
Engineers Way
Wembley
HA9 0FJ

TEL (020) 8937 5364
FAX
EMAIL colin.wickes@brent.gov.uk
WEB <http://www.brent.gov.uk>
OUR REF: 1707179

DATE: 12th August 2013

Mr Jose Manuel Rocha
70 Beaufort Court
Richmond
Surrey
TWA 7YQ

Licensing Act 2003
Application for a Premises Licence
Grill 4 You 758 Harrow Road London NW10 5LE

Dear Mr Rocha

I refer to your application on behalf of your client for a Premises Licence for the above named premises. In accordance to the scaled drawing (number 001) submitted to us related to the Application, the Public Safety Team make a Representation to the Licensing Authority on the grounds of Public Safety.

Providing your client and you are willing accept the proposed licence conditions the Public Safety Team would withdraw the Representation:-

Licence Conditions

- The maximum number of persons permitted on the Ground Floor shall not exceed 60 including staff.
- Any locks or flush latches on exit doors shall be unlocked and kept free from fastenings whilst the public are on the premises.
- Any socket outlets (or other power supplies used for DJ equipment, band equipment and other portable equipment) that are accessible to performers, staff or the public shall be suitably protected by a residual current device (RCD having a rated residual operating current not exceeding 30 milliamps).

In order for the Public Safety Team to withdraw this representation, it will be necessary for you or your client to confirm in writing that the above works have been rectified and that you accept the above licence conditions.

We will require these conditions to appear on the licence schedule should the licence be granted.

If you or your client requires further clarification please do not hesitate to contact me.

Yours faithfully

Colin Wickes
Principal Public Safety Officer
Consumer & Business Protection