



Public Safety Team
Environment and Protection
Brent Civic Centre
Engineers Way
Wembley
HA9 0FJ

TEL (020) 8937 5364
FAX
EMAIL colin.wickes@brent.gov.uk
WEB <http://www.brent.gov.uk>
OUR REF: 222100846

DATE: 20th MAY 2014

Kausik Varsani
Shree Swaminarayan Mandir London
Kingsbury Road
Kingsbury
9W9 8AQ

Licensing Act 2003

Application for a Premises Licence

Shree Swaminarayan Roe Green Park Kingsbury Road London NW9

Dear Kausik Varsani

I refer to your application for a Licence to the above named Premises. In accordance to the drawing submitted to us related to the application, the Public Safety Team makes a Representation to the Licensing Authority on the grounds of Public Safety.

Providing you are willing to accept the following proposed licence conditions the Public Safety Team would withdraw the Representation:-

Licence Conditions

- The maximum number of persons permitted in the Public Arena shall not exceed **2000** not including staff.
- The 4 exits from the fenced Public Arena area shall each be at least 3.3 metres wide or additional exits with a total aggregate exit width of at least 13.2 metres shall be provided.
- An additional exit shall be provided on the Stage Left side fencing at rear of stage.
- If gates are provided on the exits they shall open in the direction of escape. Any locks on exit gates shall be unlocked and kept free from fastenings other than push bars whilst the public are on the premises.
- Any socket outlets (or other power supplies used for stage equipment, band equipment and other portable equipment) that are accessible to performers, staff or the public shall be suitably protected by a residual current device (RCD having a rated residual operating current not exceeding 30 milliamps).

- The seating depth back to back dimension between rows of seats where backs are provided should be at least 760mm deep but for comfort it is good practice to provide at least 900mm. Where backs to seats are not provided at least 600mm depth should be provided.
- The width of the seats where arms are provided shall be at least 500mm or where arms are not provided a width of at least 450mm shall be provided.
- The width of wheelchair spaces shall be at least 900mm and 1400mm in depth.
- The clear seat-way shall not be less than 300mm but if there are more than 24 seats in a row there shall be at least 450mm of clear seat-way.
- The seating gangways form part of the means of escape and shall be at least 1100mm wide.
- The seating shall be firmly fixed to the floor and fixed together to ensure that the rows do not separate and snake under pressure.
- If the seating is on a raised platform the structure shall be certified to comply with the expected crowd loading. Suitably crowd loaded balustrades shall be provided at any edges above 300mm from the ground. Any gaps under the seats where children could fall through to the ground shall be suitably enclosed.
- The stage platform and roof structure shall be installed and certified in accordance with the Temporary Demountable Structures Guidance issued by the Institute of Structural Engineers.
- The Electrical and lighting installations shall be installed by competent engineers and be inspected/provided with a completion certificate once all work is completed.
- Both normal, emergency lighting and illuminated Exit signs shall be installed throughout the public and staff areas.

In order for the Public Safety Team to withdraw this representation, it will be necessary for you to **confirm in writing that you will accept the above licence conditions and will ensure the required works are carried out before the public attend the premises.**

We will require these conditions to appear on the licence schedule should the application be granted.

Yours faithfully

Colin Wickes
Principal Public Safety Officer
Environment and Protection