

APPENDIX 2

From: Miller-Johnson, Lavine
Sent: 22 August 2013 14:25
To: 'almorfr@hotmail.com'
Subject: Visit-31 Station Road

Dear Mr Rodrigues,

Further to our visit on 20th August 2013 I am emailing you in regards to the issues found on site. The new area outside at the rear of the premise will need to be included on the plan. You will need to do this by filling out a premise variation application online and include a new plan to be submitted to the council. You will also need to consult the planning department to ensure that this new area meets regulations.

Your fire exit at the rear does not meet regulations. The door needs to be a fire door that opens outwards with a push bar. There must not be any locks or bolts fastenings on the door.

Please apply to vary the licence premises licence as soon as possible to avoid further council action.

A further visit will be made to ensure my requests have been carried out.

If you need further advise please do not hesitate to contact me.

Lavine Miller-Johnson
Licensing Officer
Safer Streets
Brent Council
0208 937 5359