

**From:** Pearce, Chris  
**Sent:** 31 May 2018 15:58  
**To:** 'Elliot Milne'; Business Licence; Legister, Linda  
**Subject:** RE: Milk Beach Cafe & Restaurant, 19 Lonsdale Road, NW6 6RA - 12033

Dear Mr Elliot Milne

**New Premises - Milk Beach Cafe & Restaurant, 19 Lonsdale Road, NW6 6RA - 12033**  
**Please find the amended conditions below.**

I refer to the application for a new licence for the above named premises. After assessing the application, the Public Safety Team will be making the following representations to the Licensing Authority on the grounds of Public Safety.

Providing the licensee is willing to accept the following conditions Public Safety Team would withdraw the representation.

- The locks and flush latches on the exit doors and gates shall be unlocked and kept free from fastenings other than push bars or pads whilst the public are on the premises bar the two barn door style doors that maybe left open or locked when the public are on the premises.
- The socket outlets (or other power supplies used for DJ equipment, band equipment and other portable equipment) that are accessible to performers, staff or the public shall be suitably protected by a residual current device (RCD having a rated residual operating current not exceeding 30 milliamps).
- Exits are not obstructed (including by curtains, hangings or temporary decorations), and accessible via non-slippery and even surfaces, free of trip hazards and clearly identified
- Where chairs and tables are provided, internal gangways are kept unobstructed

In order for the Public Safety Team to withdraw this representation, it will be necessary for you or your client to confirm in writing or via Email that you accept the above licence conditions.

We will require this condition to appear on the licence schedule should the licence be granted.

Please note that the setting of the capacity for the premises and means of escape in case of fire are dealt with by the London Fire Brigade and you are advised to contact them regarding those matters. However, based on the available floor area of 60m<sup>2</sup>, the maximum number of customers permitted on the premises at any one time (excluding staff) is 60.

If you are in control of any part of a commercial premises, you are required to carry out a fire risk assessment to identify hazards and risks in the premises, and take effective measures to reduce those risks. A fire risk assessment is essential in keeping your premises safe for everyone. You must keep a written record of your fire risk assessment if your business has five or more people.

More information can be found at: <http://www.london-fire.gov.uk/FireRiskAssessment.asp>

Kind regards

Mr Chris Pearce  
Public Safety Officer  
Regeneration & Environmental Services  
Brent Council