

From: Pearce, Chris
Sent: 07 August 2018 16:04
To: 'licensing@narts; Business Licence; Legister, Linda
Subject: RE: CONSULT - New Premises Licence - Lezziz Charcoal Grill, 13-15 Walm Lane, Willesden, NW2 5SJ

Dear Sirs

Licensing Act 2003

Application for a New Premises Licence

Premises address New Premises Licence - Lezziz Charcoal Grill, 13-15 Walm Lane, Willesden, NW2 5SJ

I refer to your application for a premises licence for the above premises. The Public Safety Team is making a Representation to the Licensing Authority on the grounds of public safety.

Providing you are willing to accept the following proposed licence condition the Representation will be withdrawn.

Licence Condition

1. The socket outlets or other power supplies used for DJ equipment, band equipment and other portable equipment that are accessible to performers, staff or the public shall be suitably protected by a residual current device (RCD) having a rated residual operating current not exceeding 30 milliamps.
2. Any locks or flush latches on exit doors shall be unlocked and kept free from fastenings other than push bars whilst the public are on the premises.
3. kitchen doors must provide half hour fire protection and be fitted with a self-closing device.
4. On exit doors any locks or flush latches shall be unlocked and kept free from fastenings other than push bars or pads whilst the public are on the premises.
5. Provide highlighted and clearly visible nosings' to the stairs leading from ground floor to the mezzanine level to prevent trips and falls to customers and staff. Provide adequate lighting to this area.
6. Subject to risk assessment, the maximum number of persons permitted on the Premises (not including staff) shall be: 175

In order for the Public Safety Team to withdraw this representation, it will be necessary for you to **confirm in writing or via Email** that you accept the above licence condition.

We will require this condition to appear on the licence schedule should the licence be granted.

Please note that the setting of the capacity for the premises and means of escape in case of fire is dealt with by the London Fire Brigade and you are advised to contact them regarding those matters.

If you are in control of any part of a commercial premise, you are under a legal obligation to carry out a detailed fire risk assessment to identify risks and hazards in the premises. A fire risk assessment is essential in keeping your

premises safe for everyone. You must keep a written record of your fire risk assessment if your business has five or more people.

More information can be found here: <http://www.london-fire.gov.uk/FireRiskAssessment.asp>

Please let me know if I can assist you further.

Kind regards

Mr Chris Pearce
Public Safety Officer
Regeneration & Environmental Services
Brent Council
020 8937 1031