

From: Pearce, Chris
Sent: 12 September 2018 15:48
To: 'bekirkara; Legister, Linda; Business Licence
Subject: Shawarma Grill, 350-352 High Road, Wembley, HA9 6AZ - Ref: 13177

Dear Mr Kara

Licensing Act 2003

Application for a New Premises Licence

Premises address: Shawarma Grill, 350-352 High Road, Wembley, HA9 6AZ - Ref: 13177

I refer to your application for a premises licence for the above premises. The Public Safety Team is making a Representation to the Licensing Authority on the grounds of public safety.

Providing you are willing to accept the following proposed licence condition the Representation will be withdrawn.

Licence Condition

- The locks and flush latches on the exit doors and gates shall be unlocked and kept free from fastenings other than push bars or pads whilst the public are on the premises.

- The socket outlets (or other power supplies used for DJ equipment, band equipment and other portable equipment) that are accessible to performers, staff or the public shall be suitably protected by a residual current device (RCD having a rated residual operating current not exceeding 30 milliamps).

- Exits are not obstructed (including by curtains, hangings or temporary decorations), and accessible via non-slippery and even surfaces, free of trip hazards and clearly identified

- Where chairs and tables are provided, internal gangways are kept unobstructed

Kind regards

Mr Chris Pearce
Public Safety Officer
Regeneration & Environmental Services
Brent Council
020 8937 1031