

**From:** Pearce, Chris  
**Sent:** 22 October 2018 11:02  
**To:** ENS Public Safety <ens.publicsafety@brent.gov.uk>; 'Shital' shailender nagpal Legister, Linda <Linda.Legister@brent.gov.uk>  
**Cc:** Mayank patel Gets  
**Subject:** RE: CONSULT - New Premises - Satyanarayan, 23-25 Queensbury Station Parade - 13499

Dear Sirs

**RE: Licensing Act 2003**  
**Application for the Grant of a New Premises Licence**  
**New Premises - Satyanarayan, 23-25 Queensbury Station Parade – 13499**

I refer to the application for a new licence for the above named premises. After assessing the application, the Public Safety Team will be making the following representations to the Licensing Authority on the grounds of Public Safety.

Providing the licensee is willing to accept the following conditions Public Safety Team would withdraw the representation.

- The locks and flush latches on the exit doors and gates shall be unlocked and kept free from fastenings other than push bars or pads whilst the public are on the premises.
- The socket outlets (or other power supplies used for DJ equipment, band equipment and other portable equipment) that are accessible to performers, staff or the public shall be suitably protected by a residual current device (RCD having a rated residual operating current not exceeding 30 milliamps).
- Exits are not obstructed (including by curtains, hangings or temporary decorations), and accessible via non-slippery and even surfaces, free of trip hazards and clearly identified
- Where chairs and tables are provided, internal gangways are kept unobstructed
- Temporary electrical wiring and distribution systems are not provided without notification to the licensing authority at least ten days before commencement of the work and/or prior inspection by a suitable qualified electrician.
- Subject to risk assessment, the maximum number of persons permitted on the Premises (not including staff) shall be: 150 persons

In order for the Public Safety Team to withdraw this representation, it will be necessary for you or your client to **confirm in writing or via Email** that you accept the above licence conditions.

We will require these conditions to appear on the licence schedule should the licence be granted.

*If you are in control of any part of a commercial premise, you are under a legal obligation to carry out a detailed fire risk assessment to identify risks and hazards in the premises. A fire risk assessment is essential in keeping your premises safe for everyone. You must keep a written record of your fire risk assessment if your business has five or more people.*

More information can be found here: <http://www.london-fire.gov.uk/FireRiskAssessment.asp>

Please let me know if I can assist you further.

Kind regards

Mr Chris Pearce  
Public Safety Officer  
Regeneration & Environmental Services  
Brent Council  
020 8937 1031