

From: ENS Public Safety
Sent: 15 August 2019 09:20
To: Jolly, Lorna <Lorna.Jolly@shoosmiths.co.uk>; ENS Public Safety <ens.publicsafety@brent.gov.uk>; Legister, Linda <Linda.Legister@brent.gov.uk>; Business Licence <business.licence@brent.gov.uk>; Patel, Yogini <Yogini.Patel@brent.gov.uk>
Subject: RE: CONSULT: New Premises - McDonald's Restaurants, Forty Lane, HA9 9EX - 16965

Good morning Lorna

Thank you for taking the time to discuss this application last week.

I can confirm that the Public Safety Team will withdraw its representations.

Kind regards

Mr Chris Pearce
Public Safety Officer
Regeneration & Environmental Services
Brent Council
020 8937 1031

www.brent.gov.uk
[@Brent_Council](https://twitter.com/Brent_Council)

From: Jolly, Lorna [<mailto:Lorna.Jolly@shoosmiths.co.uk>]
Sent: 12 August 2019 11:45
To: ENS Public Safety ; Legister, Linda ; Business Licence ; Patel, Yogini
Subject: RE: CONSULT: New Premises - McDonald's Restaurants, Forty Lane, HA9 9EX - 16965

Good morning Chris,

I refer to our conversation last week regarding changing the below conditions to take into consideration the fact that the McDonald's is inside of the actual supermarket.

Are you able to confirm if you have had a chance to rethink them please?

I look forward to hearing from you.

Many thanks,
Lorna

Lorna Jolly
Paralegal

SHOOSMITHS LLP

03700 86 1954 **UK direct dial**
+44 (0) 160 454 1954 **Int. direct dial**

Follow us on [LinkedIn](#)

View our latest legal updates on Twitter: [@shoosmithslaw](#)

View news about Shoosmiths on Twitter: [@shoosmiths](#)

www.shoosmiths.co.uk

From: ENS Public Safety [<mailto:ens.publicsafety@brent.gov.uk>]

Sent: 06 August 2019 12:36

To: Jolly, Lorna <Lorna.Jolly@shoosmiths.co.uk>; Legister, Linda <Linda.Legister@brent.gov.uk>;
Business Licence <business.licence@brent.gov.uk>; Patel, Yogini <Yogini.Patel@brent.gov.uk>

Subject: FW: CONSULT: New Premises - McDonald's Restaurants, Forty Lane, HA9 9EX - 16965

Dear Lorna Jolly

I refer to the application for a new licence for the above named premises. After assessing the application, the Public Safety Team will be making the following representations to the Licensing Authority on the grounds of Public Safety.

Providing the licensee is willing to accept the following conditions Public Safety Team would withdraw the representation.

1. The locks and flush latches on the exit doors shall be unlocked and kept free from fastenings other than push bars or pads whilst the public are on the premises.
2. Any socket outlets (or other power supplies used for DJ equipment, band equipment and other portable equipment) that are accessible to performers, staff or the public shall be suitably protected by a residual current device (RCD having a rated residual operating current not exceeding 30 milliamps).
3. No person shall be permitted to sit on the floor, on stairs or in gangways and passageways.
4. All roller shutters that are operational as exit points must be fixed/locked up in the open position whilst the public/staff are on the premises.
5. A capacity specific risk assessment shall be conducted by a professionally qualified risk assessor. This assessment will include holding capacity, exit capacity and the calculations to demonstrate how that was reached, the lower of the two numbers shall be the final capacity. The guidance used to reach this capacity must be quoted. This risk assessment shall be appraised annually or at the time of any building or layout structural works.

Please provide the capacity assessment when available.

In order for the Public Safety Team to withdraw this representation, it will be necessary for you or your client to **confirm in writing or via Email** that you accept the above licence conditions.

We will require these conditions to appear on the licence schedule should the licence be granted.

Please let me know if I can assist you further.

Kind regards

Mr Chris Pearce
Public Safety Officer
Regeneration & Environmental Services
Brent Council
020 8937 1031

www.brent.gov.uk

[@Brent_Council](#)