

From: Pearce, Chris <Chris.Pearce@brent.gov.uk>
Sent: 07 October 2019 10:12
To: licensingservicesagency; Legister, Linda <Linda.Legister@brent.gov.uk>; Business Licence <business.licence@brent.gov.uk>; Patel, Yogini <Yogini.Patel@brent.gov.uk>
Subject: RE: FW: CONSULT: Variation - Ceylon, 32 Ealing Road, HA0 4TL - 17360

Dear Debra,

Unfortunately I am unable to recommend any contractors but I would recommend looking at the HSE website for information/guidance.

With regards to the conditions, I would need all four to be accepted before I can withdraw my representations.

Kind regards

Mr Chris Pearce
Public Safety Officer

From: licensingservicesagency
Sent: 04 October 2019 16:46
To: Pearce, Chris
Subject: RE: FW: CONSULT: Variation - Ceylon, 32 Ealing Road, HA0 4TL - 17360

Dear Chris

I have been through the conditions with the applicant and conditions 1 and 3 are fine. With regard to condition 2 they do not currently have any live music or DJs but will ensure that if they decide to start providing live music they will ensure that the socket outlets are suitably protected.

With regard to condition 4 the applicant does not know of any risk assessors so if you could advise me of any competent assessor that could do this for them please let me know and I will pass on this information, and then once a risk assessment has been made they will be able to comply with this condition.

Kind regards

Debra Silvester

On 03 October 2019 at 11:31 "Pearce, Chris" <Chris.Pearce@brent.gov.uk> wrote:

Dear Debra Silvester

I refer to the application for a new licence for the above named premises. After assessing the application, the Public Safety Team will be making the following representations to the Licensing Authority on the grounds of Public Safety.

Providing the licensee is willing to accept the following conditions Public Safety Team would withdraw the representation.

1. The locks and flush latches on the exit doors shall be unlocked and kept free from fastenings other than push bars or pads whilst the public are on the premises.
2. Any socket outlets (or other power supplies used for DJ equipment, band equipment and other portable equipment) that are accessible to performers, staff or the public shall be suitably protected by a residual current device (RCD having a rated residual operating current not exceeding 30 milliamps).
3. No person shall be permitted to sit on the floor, on stairs or in gangways and passageways.
4. A capacity specific risk assessment shall be conducted by a competent risk assessor. This assessment will include holding capacity, exit capacity and the calculations to demonstrate how that was reached, the lower of the two numbers shall be the final capacity. The guidance used to reach this capacity must be quoted. This risk assessment shall be appraised annually or at the time of any building or layout structural works. The Capacity Assessment must be made available to an authorised officer upon request.

In order for the Public Safety Team to withdraw this representation, it will be necessary for you or your client to **confirm in writing or via Email** that you accept the above licence conditions.

We will require these conditions to appear on the licence schedule should the licence be granted.

Please let me know if I can assist you further.

Kind regards

Mr Chris Pearce
Public Safety Officer
Regeneration & Environmental Services