

Good Afternoon Ewen

1. Portable electrical equipment brought into the premises must be suitably protected by a residual current device (RCD) having a rated residual operating current not exceeding 30 milliamps. This is for the protection of the public.
2. As stated the current conditions no longer apply as this is a new application so a new capacity calculation will need to be provided. This would be standard for all new applications.

If you have any questions please do not hesitate in contacting me.

Kind regards

Mr Chris Pearce
 Public Safety Officer
 Regeneration & Environmental Services

From: Ewen Macgregor
Sent: 08 November 2019 10:59
To: Pearce, Chris
Cc: Patel, Yogini
Subject: THE BAD AXE THROWING COMPANY LIMITED (THE533/1)

Morning Chris

Hope all is well

Wonder if you have had a chance to look at the email below?

I look forward to hearing from you

Ewen Macgregor
 Associate Director
 Head of Regulatory and Licensing

From: Ewen Macgregor
Sent: 31 October 2019 15:06
To: 'Pearce, Chris'
Subject: THE BAD AXE THROWING COMPANY LIMITED (THE533/1)

Afternoon Chris

My clients have asked me to ask about the need/requirement for the condition below – are you able to confirm so that I can pass the information on to them:

The socket outlets (or other power supplies used for DJ equipment, band equipment and other portable equipment) that are accessible to performers, staff or the public shall be suitably protected by a residual current device (RCD) having a rated residual operating current not exceeding 30 milliamps).

In so far as the capacity condition is concerned – below – can you confirm that this will be in place of the current condition on the licence which restricts the capacity to 129?

A capacity specific risk assessment shall be conducted by a competent risk assessor. This assessment will include holding capacity, exit capacity and the calculations to demonstrate how that was reached, the lower of the two numbers shall be the final capacity. The guidance used to reach this capacity must be quoted. This risk assessment shall be appraised annually or at the time of any

building or layout structural works. The Capacity Assessment must be made available to an authorised officer upon request.

I look forward to hearing from you

Best wishes

Ewen Macgregor
Associate Director
Head of Regulatory and Licensing

From: ENS Public Safety <ens.publicsafety@brent.gov.uk>

Sent: 28 October 2019 10:27

To: naomi.jenkins; Patel, Yogini <Yogini.Patel@brent.gov.uk>; Legister, Linda <Linda.Legister@brent.gov.uk>; Business Licence <business.licence@brent.gov.uk>

Subject: FW: CONSULT: New Premises - Bad Axe Throwing, Unit 32-33 Boxpark, 18 Olympic Way, HA9 0JT - 17749

Dear Ms Jenkins

I refer to the application for a new licence for the above named premises. After assessing the application, the Public Safety Team will be making the following representations to the Licensing Authority on the grounds of Public Safety.

Providing the licensee is willing to accept the following conditions Public Safety Team would withdraw the representation.

1. The locks and flush latches on the exit doors shall be unlocked and kept free from fastenings other than push bars or pads whilst the public are on the premises.
2. Any socket outlets (or other power supplies used for DJ equipment, band equipment and other portable equipment) that are accessible to performers, staff or the public shall be suitably protected by a residual current device (RCD having a rated residual operating current not exceeding 30 milliamps).
3. No person shall be permitted to sit on the floor, on stairs or in gangways and passageways.
4. A capacity specific risk assessment shall be conducted by a competent risk assessor. This assessment will include holding capacity, exit capacity and the calculations to demonstrate how that was reached, the lower of the two numbers shall be the final capacity. The guidance used to reach this capacity must be quoted. This risk assessment shall be appraised annually or at the time of any building or layout structural works. The Capacity Assessment must be made available to an authorised officer upon request.

In order for the Public Safety Team to withdraw this representation, it will be necessary for you or your client to **confirm in writing or via Email** that you accept the above licence conditions.

We will require these conditions to appear on the licence schedule should the licence be granted.

Please let me know if I can assist you further.

Kind regards

Mr Chris Pearce
Public Safety Officer
Regeneration & Environmental Services