

From: Pearce, Chris <Chris.Pearce@brent.gov.uk>
Sent: 04 March 2020 17:01
To: Khuram Shabbir; Legister, Linda <Linda.Legister@brent.gov.uk>; Business Licence <business.licence@brent.gov.uk>; Patel, Yogini <Yogini.Patel@brent.gov.uk>
Subject: RE: CONSULT: New Premises - Pasha London Ltd, Unit 2 Darwin House, 1120 Harrow Road, NW10 5NA - 18456

Dear Khuram

Thank you for your correspondence dated 4th March 2020, stating that you accept the conditions set out in our representation.

Please ensure that the capacity calculations are forwarded to the Public Safety Team as soon as available to prevent delay in the licence can be issued.

I confirm that the Public Safety Team now withdraw the current representation and do not make any further representations regarding the application.

We will require the agreed conditions to appear on the licence schedule.

Kind regards

Mr Chris Pearce
Public Safety Officer

From: Khuram Shabbir
Sent: 04 March 2020 16:48
To: Pearce, Chris
Subject: Re: CONSULT: New Premises - Pasha London Ltd, Unit 2 Darwin House, 1120 Harrow Road, NW10 5NA - 18456

Dear Chris,

We agree to the conditions set out below thank you. If you could kindly withdraw your representations please thank you.

Kind regards,
Khuram shabbir

From: Pearce, Chris <Chris.Pearce@brent.gov.uk>
Sent: 03 March 2020 16:49:21
To: ENS Public Safety <ens.publicsafety@brent.gov.uk>; <khuram505>; Business Licence <business.licence@brent.gov.uk>; Legister, Linda <Linda.Legister@brent.gov.uk>; Patel, Yogini <Yogini.Patel@brent.gov.uk>
Subject: RE: CONSULT: New Premises - Pasha London Ltd, Unit 2 Darwin House, 1120 Harrow Road, NW10 5NA - 18456

Dear sirs

This is a reminder that in order for me to withdraw my representations you will need to agree in writing or via email to the conditions set out below.

Kind regards

Mr Chris Pearce
Public Safety Officer

From: ENS Public Safety

Sent: 27 February 2020 10:56

To: 'khuram505 <Business Licence <business.licence@brent.gov.uk>; Legister, Linda <Linda.Legister@brent.gov.uk>; Patel, Yogini <Yogini.Patel@brent.gov.uk>

Subject: FW: CONSULT: New Premises - Pasha London Ltd, Unit 2 Darwin House, 1120 Harrow Road, NW10 5NA - 18456

Dear Sirs

I refer to the application for a new licence for the above named premises. After assessing the application, the Public Safety Team will be making the following representations to the Licensing Authority on the grounds of Public Safety.

Providing the licensee is willing to accept the following conditions Public Safety Team would withdraw the representation.

1. The locks and flush latches on the exit doors shall be unlocked and kept free from fastenings other than push bars or pads whilst the public are on the premises.
2. Any socket outlets (or other power supplies used for DJ equipment, band equipment and other portable equipment) that are accessible to performers, staff or the public shall be suitably protected by a residual current device (RCD having a rated residual operating current not exceeding 30 milliamps).
3. No person shall be permitted to sit on the floor, on stairs or in gangways and passageways.
4. A capacity specific risk assessment shall be conducted by a competent risk assessor. This assessment will include holding capacity, exit capacity and the calculations to demonstrate how that was reached, the lower of the two numbers shall be the final capacity. The guidance used to reach this capacity must be quoted. This risk assessment shall be appraised annually or at the time of any building or layout structural works. The Capacity Assessment must be made available to an authorised officer upon request.

In order for the Public Safety Team to withdraw this representation, it will be necessary for you or your client to **confirm in writing or via Email** that you accept the above licence conditions.

We will require these conditions to appear on the licence schedule should the licence be granted.

Please provide the capacity calculations as soon as they are completed to prevent a delay in the license being granted.

I have been informed that you already have a capacity assessment that would allow for 70 persons. As you only have one (1) entry/exit point this would be a maximum of 60 persons assuming there is suitable space inside.

Please let me know if I can assist you further.

Kind regards

Mr Chris Pearce
Public Safety Officer